

Field Certification Certificate of Compliance

Certificate: 2471385

Master Contract:

Project: 2471385

Date Issued: draft

Issued to: Sirio Sistemi Elettronici SpA
Via Fleming 16
59100 Prato
ITALY

Attention: Mr Iacopo Querci

*The products listed below are eligible to bear CSA Field Certification Labels,
bearing the CSA Mark shown..*



Issued by: E.Giustii

PRODUCTS

Class No: 2258 82 PROCESS CONTROL for hazardous locations – to US requirements

Class I Division 2 Groups C, D Temperature Code T3

Control panel model UCP Serial Number 310164 and Junction Box model BOP (Balance of Plant). Electrical ratings: 120 Vac, 20A, 60 Hz, 1 phase.

Enclosure rating: Type 4X.

Ambient temperature range: $-30^{\circ}\text{C} < T_a < +40^{\circ}\text{C}$

2 CSA Field Certification Labels FB492763 and FB492764 issued

Location: Spectra Project - USA

Certificate: 24713850

Master Contract:255145

Project: 24713850

Date:draft

APPLICABLE REQUIREMENTS

The specific products described in this report were evaluated against:

UL 508

Seventeenth Edition Industrial Control Equipment.

ANSI/ISA 12.12.01

Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

MARKINGS

- 1) Submitter's name, trademark
- (2) Catalogue / Model designation.
- (3) Complete electrical rating (amps, hertz, and volts).
- (4) Date code / Serial number traceable to month and year of manufacture.
- (5) Hazardous Location designations.
- (6) Temperature code.
- (7) Maximum ambient.
- (8) The following cautions:

- Close the window after finishing operation on the Allen Bradley Panel View
- Wipe clean only with a moist cloth (Beware of electrostatic charges)
- This enclosure must not be opened unless the area atmosphere is known to be NON hazardous or unless all devices within have been de-energized.
- Explosion Hazard: Substitution of Components May Impair Suitability for Class I, Division 2
- Do NOT open under Load Open the appropriate circuit breaker to isolate



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 2471385

Master Contract:

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
2471385	draft	Original Field Certification. 2 Field Certification Labels issued: Serial number FB492763 FB492764 (total of 2 labels) Report issued.